

# **Future Water Supply**

Creative Solutions for Water Challenges



### **Project History**

Water source life study

**High Plains Water District grant** 

Test hole – 1,245 ft deep

Water quality testing

Study of system feasibility

Find water supply for 50 – 75 years







# Santa Rosa Vs. Ogallala Well

Cost

Design

Construction

**Water Quality** 

Knowledge

#### 4.9 Minimum Spacing Requirements

(a) All wells permitted subsequent to the date of enactment of this rule shall meet the following distance and production limitations:

Table 1 Minimum Spacing of Wells in the Ogallala/Edwards-Trinity (High Plains) Aquifer

Well Production	Minimum Distance from nearest valid well or proposed well site located in the Ogallala /Edwards-Trinity (High Plains) Aquifer	Minimum Distance from nearest property line
17.5 to 70 gpm	100 yards	25 yards
>70 up to 165 gpm	200 yards	50 yards
>165 up to 265 gpm	300 yards	75 yards
>265 up to 390 gpm	350 yards	87.5 yards
>390 up to 560 gpm	400 yards	100 yards
>560 up to 1,000 gpm	500 yards	125 yards
>1,000 gpm	540 yards	135 yards


Table 2 Minimum Spacing of Wells in the Dockum Aquifer

Well Production	Minimum Distance from nearest valid well or proposed well site located in Dockum Aquifer	Minimum Distance from nearest property line		
17.5 up to 70 gpm	100 yards	25 yards		
>70 up to 165 gpm	200 yards	50 yards		
>165 up to 265 gpm	300 yards	75 yards		
>265 up to 500 gpm	880 yards	100 yards		
>500 gpm	1760 yards	135 yards		





### Santa Rosa Vs. Ogallala Well




0MENSION (FT) MED. NO. A B II 1 BSC 240 610

MOTES.


1. ELEVATIONS SHOWN ARE APPROXIMATE


- 2. HE CASING SHALL BE TO NEW ASTM A-53 STEEL WITH A MINIMUM WALL THICKNESS OF 3/8".
- 3. THE DRILL HOLE SHALL HAVE A MINIMUM DVMETER OF 21".
- 4. THE CONTRACTOR SHALL GROUT THE JASKA BETWEEN THE WALL OF THE GROLL HOLE AND THE CASHS FROM THE SURFACE TO APPROXIMATELY SSC FT.
- 5 THE WOLL SCREEN SLOT SIZE SHALL BE 3/8" x8" THERE WILL BE 8 SLOTS/FT. B. SSE DIMENSION TABLE THIS SHEET.



NOTES

- CONCRETE FOR PLMP TO BE PLACED MOROLITHICALLY
- CONCRETE TO BE 3000 P.S.I.-28 DAY
- CONCRETE SCAR SHALL SKOPE AWAY FROM WELLHEAD IN ALL DIRECTIONS AT 1/4" FER FOOT.






FOUNDATION PLAN



CITY OF

## **Water Supply System**





8-7-14

Project No:

### **Current Water Supply**


City supplied by groundwater from Ogallala Peak 980 gpm

Declines in water levels: 20 year supply

Industrial use increases 400 gpm








Water-level changes in the High Plains aquifer, predevelopment to 2013



### Out of Town Option for Santa Rosa Well





8-7-14



# **Preliminary Layout of System**







In Town Option for Santa Rosa Well

LEGEND







### **Brackish Water Supply and Treatment**

3,000 mg/L TDS water, normally 0-1,000 mg/L



\$6.7 Million estimated cost

**Increases water supply** 

**Costly treatment** 

**Utilizes existing infrastructure** 



Seminole and Wheeler have RO plants currently



### **Preliminary Opinion of Construction Costs**



City of Abernathy
Water System Improvements
Brackish Water Desalinization
Preliminary Opinion of Probable Construction Cost
May 5, 2016



Item No.	<u>Description</u>	<u>Unit</u>	Quantity	<u>Unit Price</u>	<u>Extension</u>	
	New Water Brackish Treatment Plant		->			
1	Mobilization/Demobilization	LS	1	\$115,000	\$115,00	
2	Site Work (Access Road/Grading of Site/Concrete Paving)	LS	1	\$15,000	\$15,00	
3	Reverse Osmosis (250 gpm permeate) Skid-Mounted Unit	EA	2	\$280,000	\$560,00	
4	RO Membranes/Elements (8"x40", high pressure)	EA	120	\$600	\$72,00	
5	Clean-in-Place Skid Unit	EA	1	\$64,270	\$64,27	
6	Booster Feed Pump Skid	EA	2	\$104,980	\$209,96	
7	Chemical Feed Skids (Anti-Scalant and Caustic)	EA	3	\$24,750	\$74,25	
8	Building improvements and piping	Building improvements and piping LS 1 \$85,0		\$85,000	\$85,00	
9	New GST for Concentrate Water (50,000 gal)	EA	1	\$75,000	\$75,00	
10	Booster Pump Skid for Concentrate	EA	1	\$90,000	\$90,00	
12	Electrical (Site and Building)	LS	1	\$170,000	\$170,00	
13	Generator	LS	1	\$180,000	\$180,00	
14	Yard Piping, Valves, Fittings, Meters	LS	1	\$150,000	\$150,00	
15	Pre-Cast Concrete (Vaults, Outfall, Manhole)	LS	1	\$54,000	\$54,00	
16	Chlorine System	LS	1	\$45,000	\$45,00	
17	PVC Water Line / Discharge Structure for Stream Discharge	LF	17,253	\$52	\$897,13	
			\$571,30			
				Subtotal	\$3,427,90	
	New Water Brackish Water Supply Infrastructure					
18	Brackish Water Well (880 yard spacing)	EA	3	\$750,000	\$2,250,00	
19	Collection Piping	LF	7,180	\$65	\$466,70	
Contingency and Inflation						
				Subtotal	\$3,260,040.0	
Opinion of Probable Construction Cost						

<sup>\*</sup>For preliminary use only. Not to be used for construction permitting or other construction purposes.





<sup>\*\*</sup>Estimate does not include land or right-of-way costs

<sup>\*\*\*</sup>Estimate does not include engineering, surveying, testing or construction representation

#### **New Wastewater Plant for Reuse**

Reuse of the existing water resource

**Mechanical for consistent quality** 

**\$6 Million estimated cost** 

Utilizes existing ponds and application area









### Water Resource Planning



#### **Projects are 3-5 year timeframe**

#### Add to resources or extend current resources

		Current Operational			
Well	Total Depth (ft)	Saturated Thickness (ft)	Total Decline (ft)	Avg. Yearly Decline (ft/yr)	Well Life Remaining (Yr)
1	285	18.3	-72.7	-1.5	6.6
4	397	124.7	-54.3	-1.4	44.8
5	351	41.2	-94.8	-2.8	14.8
6	358	51.5	-93.5	-2.8	18.5
7	330	34.6	-27.3	-5.5	12.4
Well Fi	ield Average	54.1	-68.5	-2.8	19.4



## Questions





