

IN THE WATER LOSS AUDIT SUBMITTED TO THE TEXAS WATER DEVELOPMENT BOARD FOR THE TIME PERIOD OF JAN – DEC 2025. OUR SYSTEM LOST AN ESTIMATED OF 11%. IF YOU HAVE ANY QUESTIONS ABOUT WATER LOSS AUDIT CALL 806 – 298- 2546 OR 806 -778 -4916.

PUBLIC PARTICIPATION OPPORTUNITIES

DATE: JULY 7 -2026

TIME : 9:00 A.M.

LOCATION: CITY HALL 811 AVE D

PHONE: 806 – 298-2546

CONTACT : PAUL GONZALEZ – RICKY PATTERSON AT 806 -778-4916 OR 806 -778-6424.

TO LEARN ABOUT FUTURE PUBLIC MEETINGS, CONCERNING YOUR DRINKING WATER OR TO REQUEST TO SCHEDULE ONE , PLEASE CALL US.

WHERE DO WE GET OUR DRINKING WATER?

THE SOURCE OF DRINKING WATER USED BY THE CITY OF ABERNATHY MUNICIPAL WATER SYSTEM IS GROUND WATER.

THE TCEQ COMPLETED AN ASSESSMENT OF YOUR SOURCE WATER AND RESULTS INDICATED THAT SOME OF YOUR SOURCES ARE SUSCEPTIBLE TO CERTAIN CONTAMINANTS. THE SAMPLING REQUIREMENTS FOR YOUR WATER SYSTEM ARE BASED ON THIS SUSCEPTIBILITY AND PREVIOUS SAMPLE DATA. ANY DETECTION OF THESE CONTAMINANTS MAY BE FOUND IN THIS CONSUMER CONFIDENCE REPORT. FOR MORE INFORMATION ON SOURCE WATER ASSESSMENTS AND PROTECTION EFFORTS AT OUR SYSTEM, CONTACT PAUL GONZALEZ, 806-298-2717 OR 806-778-4916.

FOR MORE INFORMATION ABOUT YOUR SOURCES OF WATER, PLEASE REFER TO SOURCE WATER ASSESSMENT VIEWER AVAILABLE AT THE FOLLOWING URL; <http://www.tceq.texas.gov/gis/swaview>.

FURTHER DETAILS ABOUT SOURCES AND SOURCE-WATER ASSESSMENTS ARE AVAILABLE IN DRINKING WATER WATCH AT THE FOLLOWING URL; <http://dww2.tceq.texas.gov/DWW>

SOURCE WATER NAME	LOCATION	TYPE WATER
WELL 1	ABERNATHY MUNICIPAL AIRPORT	GW - OGALLALA
WELL 4	FM 54 / HALE COUNTY RD U	GW - OGALLALA
WELL 5	FM 400 / FM 54, SE CORNER	GW - OGALLALA
WELL 7	FM 400 / FM54, SW CORNER	GW - OGALLALA
WELL 6	FM 400 / FM 54, SE CORNER	GW - OGALLALA
WELL 8	FM 54 / HALE COUNTY RD U	GW - OGALLALA

THIS IS AN ALERT ABOUT YOUR DRINKING WATER AND COSMETIC DENTAL PROBLEM THAT MIGHT AFFECT CHILDREN UNDER NINE YEARS OF AGE. AT LOW LEVELS, FLUORIDE CAN HELP PREVENT CAVITIES, BUT CHILDREN DRINKING WATER CONTAINING MORE THAN 2 MILLIGRAMS PER LITER (mg/L) OF FLUORIDE MAY DEVELOP COSMETIC DISCOLORATION OF THEIR PERMANENT TEETH (dental fluorosis). THE DRINKING WATER PROVIDED BY YOUR COMMUNITY WATER SYSTEM ABERNATHY HAS A FLUORIDE CONCENTRATION OF 2.46 MG/L

DENTAL FLUOROSIS, IN ITS MODERATE OR SEVERE FORMS, MAY RESULT IN A BROWN STAINING AND/OR OR PITTING OF THE PERMANENT TEETH. THIS PROBLEM OCCURS ONLY IN DEVELOPING TEETH, BEFORE THEY ERUPT FROM THE GUMS. CHILDREN UNDER NINE SHOULD BE PROVIDED WITH ALTERNATIVE SOURCES OF DRINKING OR WATER THAT HAS BEEN TREATED TO REMOVE THE FLURIDE TO AVOID THE POSSIBILITY OF STAINING AND PITTING

OF THEIR PERMANENT TEETH. YOU MAY ALSO WANT TO CONTACT YOUR DENTIST ABOUT PROPER USE BY YOUNG CHILDREN OF FLUORIDE-CONTAINING PRODUCTS. OLDER CHILDREN AND ADULTS MAY SAFELY DRINK THE WATER.

FOR MORE INFORMATION, PLEASE CALL PAUL GONZALEZ OF THE CITY OF ABERNATHY MUNICIPAL WATER SYSTEM AT 806-298-2717 OR 806-778-4916. SOME HOME WATER TREATMENT UNITS ARE AVAILABLE TO REMOVE FLURIDE FROM DRINKING WATER. TO LEARN MORE ABOUT AVAILABLE HOME WATER TREATMENT UNITS, YOU MAY CALL INTERNATIONAL AT 1-877-8NSF-HELP.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791. Contaminants that may be present in source water include:

A service line inventory has been prepared and can be accessed [_A COPY CAN BE VIEWED AT OUR MAIN OFFICE LOCATED AT 811 AVE D ABERNATHY, TEXAS 79311, MON-THUR 7 AM -5 PM AND FRI -8 AM-12 PM](#)

Microbial Contaminants - such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic Contaminants - such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides - which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic Chemical Contaminants - including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

Radioactive Contaminants - which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. CITY OF ABERNATHY is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact CITY OF ABERNATHY at 806-298-2968. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

In the tables below, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms, we've provided

the following definitions:

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Avg: Average - Regulatory compliance with some MCLs are based on running annual average of monthly samples.

RAA: Running Annual Average.

LRAA: Locational Running Annual Average.

mrem: millirems per year (a measure of radiation absorbed by the body).

ppb: micrograms per liter (ug/L) or parts per billion - or one ounce in 7,350,000 gallons of water.

ppm: milligrams per liter (mg/L) or parts per million - or one ounce in 7,350 gallons of water.

picocuries per liter (pCi/L): picocuries per liter is a measure of the radioactivity in water.

na: not applicable.

Disinfectant Residual

All public water systems in Texas are required to disinfect drinking water to ensure control of microbial contaminants. Disinfectants are water additives used to control microbes.

Disinfectant	Year	Average Level	Unit	Range	MRDL/MRDLG Goal
CHLORINE	2025	1.10	MG/L	.20/1.75	4/4

Regulated Contaminants

In the tables below, we have shown the regulated contaminants that were detected. Chemical Sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers back to the latest year of chemical sampling results.

Lead and Copper	Period	90TH Percentile: 90% of your water utility levels were less than	Range of Sampled Results (low - high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2021 - 2023	0.123	0.0107 - 0.298	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2021 - 2023	9.04	0.181 - 9.1	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

Disinfection Byproducts	Sample Point	Period	Highest LRAA	Range	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	801 6TH ST ABERNATHY	2025	16	15.8	ppb	60	0	By-product of drinking water disinfection
TTHM	801 6TH ST ABERNATHY	2025	2	1.96	ppb	80	0	By-product of drinking water chlorination

Regulated Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
ARSENIC	5/11/2023	5.9	5.9	ppb	10	0	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
BARIUM	5/11/2023	0.069	0.069	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
CHROMIUM	5/11/2023	1.3	1.3	ppb	100	100	Discharge from steel and pulp mills; Erosion of natural deposits
FLUORIDE	5/11/2023	2.46	2.46	ppm	4	4	Natural deposits; Water additive which promotes strong teeth.
NITRATE	6/19/2024	1.62	1.62	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Radiological Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
COMBINED URANIUM	2/13/2020	11	11	µg/L	30	0	Erosion of natural deposits

GROSS ALPHA, EXCL. RADON & U	2/13/2020	4	4	pc/L	15	0	Erosion of natural deposits
GROSS ALPHA, INCL. RADON & U	2/13/2020	11.7	11.7	pc/L	0	0	Erosion of natural deposits
GROSS BETA PARTICLE ACTIVITY	2/13/2020	15.2	15.2	pc/L	50	0	Decay of natural and man-made deposits.

Violations

During the period covered by this report we had the below noted violations.

Violation Period	Analyte	Violation Type	Violation Explanation
1/1/2025 - 6/30/2025	LEAD & COPPER RULE	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	Failed to comply with follow-up or routine tap monitoring requirements related to lead and copper
7/1/2025 - 12/31/2025	LEAD & COPPER RULE	FOLLOW-UP OR ROUTINE TAP M/R (LCR)	Failed to comply with follow-up or routine tap monitoring requirements related to lead and copper
7/1/2025 - 1/14/2026	CONSUMER CONFIDENCE RULE	CCR ADEQUACY/AVAILABILITY/CONTENT	Inadequate Consumer Confidence Report (CCR) or failure to deliver a CCR Certification form to the state on time

Additional Required Health Effects Language:

This is an alert about your drinking water and a cosmetic dental problem that might affect children under nine (9) years of age. At low levels, fluoride can help prevent cavities, but children drinking water containing more than two (2) milligrams per liter (mg/L) of fluoride may develop cosmetic discoloration of their permanent teeth (dental fluorosis). The drinking water provided by your community water system has a fluoride concentration greater than 2.0 mg/L. Dental fluorosis, in its moderate or severe forms, may result in a brown staining and/or pitting of the permanent teeth. This problem occurs only in developing teeth, before they erupt from the gums. Children under nine (9) should be provided with alternative sources of drinking water or water that has been treated to remove the fluoride to avoid the possibility of staining and pitting of their permanent teeth. You may also want to contact your dentist about proper use by young children of fluoride-containing products. Older children and adults may safely drink the water. Drinking water containing more than four (4) mg/L of fluoride (the maximum contaminant level for fluoride) can increase your risk of developing bone disease. Your drinking water does not contain more than four (4) mg/L of fluoride, but we are required to notify you when we discover that the fluoride levels in your drinking water exceed two (2) mg/L because of this cosmetic dental problem. For more information, please call at the phone number located under the heading "How might I become actively involved?" on page 1 of this report. Some home water treatment units are also available to remove fluoride from drinking water. To learn more about available home water treatment units, you may call NSF International at 1-877-8-NSF-HELP.

While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

There are no additional required health effects violation notices.